



**Oceanas**

**Lightning Protection Ltd**

49 Station Road Polegate BN26 6EA  
Tel: 01323 382387 07756 778887

**LIGHTNING PROTECTION  
CERTIFICATE OF INSPECTION**

WITH REGARD TO

**Hughenden Court  
Mount Pleasant Road  
Hastings  
TN34 3ST**

**WE HEREBY CERTIFY** that the Lightning Protection system at the above was tested in accordance with BS 6651:1999 on:

**24<sup>th</sup> July 2024**

We being the person(s) responsible for the inspection and testing of the lightning protection installation (as indicated by our signature below) particulars of which are described above, have exercised reasonable skill and care when carrying out the inspection and testing and hereby CERTIFY that the work for which we have been responsible is, to the best of our knowledge and belief in accordance with the above British Standard, except for any departures as indicated below.

Details of departures from the above British Standard:  
None

**Overall Reading: 6.82 ohms**

For and on behalf of Oceanas Lightning Protection Ltd

**G Boyce**

